

## Safety Concern with Intertek Certified Product / Souci de sécurité avec le produit certifié Intertek

### Klein Tools Non-Contact Voltage Tester Model NCVT-1

Notification Type:	Safety / Sécurité
Certification Type:	ETL Listed - US and Canada

#### Notification

Intertek notifies consumers, retailers and distributors of a potential safety concern involving the Intertek Certified products identified below. / Intertek informe les consommateurs, les détaillants et les distributeurs d'une préoccupation potentielle en matière de sécurité impliquant les produits certifiés Intertek identifiés ci-dessous.

#### Company Identification

Klein Tools

#### Product Identification

The on/off button can remain depressed during the power on or power off cycle, causing the tester to work improperly. Consumers testing electrical sources could fail to be warned of the presence of live voltage if the tester is not properly operating, posing a shock hazard to the users. The cETLus Certification Mark with control number 5000573. CPSC Recall number: 21-150 the link can be found here <https://www.cpsc.gov/Recalls/2021/Non-Contact-Voltage-Testers-Recalled-by-Klein-Tools-Due-to-Shock-Hazard#>

#### Hazard Involved

The on/off button can remain depressed during the power on or power off cycle, causing the tester to work improperly. Consumers testing electrical sources could fail to be warned of the presence of live voltage if the tester is not properly operating, posing a shock hazard to the users.

#### What To Do

Use should be immediately discontinued and return to the point of purchase. Distributors and retailers should discontinue sales and return inventories to their suppliers.

Published: June 17, 2021  
Revised:

Public Notice ID: 2021-26  
Page 2 of 2

**Photos and Images**

